Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 25/04/2019

Lab ID	:	**CP-2019-04-11-28**
Customer	:	Assistant Executive Engineer, Yelahanka Sub Division, BBMP, Bangalore.
Address	:	Yelahanka Sub Division, BBMP, Bangalore.
Project Name	:	Construction of Drain at Kote Bheedhi Near Venugopal Swamy Temple in Ward No-02 of Yelahanka Sub Division.
Agency	:	Sri.G.Muniraju, No:54, 4th Cross, 4th Main, Kote Street, Yelahanka, Bangalore-560064.
Customer's Reference	:	EE(YNK.D)E-PMT-19/W.O/31/2018-19
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	30-03-19
Customer ID	:	Drain Bottom Slab Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 25/04/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Bottom Slab Concrete	M20	28/03/2019	25/04/2019	150.93 X 149.90 X 151.47	22625	**8.444**	532.5	23.5	22.9
2	Drain Bottom Slab Concrete	M20	28/03/2019	25/04/2019	150.81 X 149.13 X 149.78	22490	**8.879**	498.7	22.2	
3	Drain Bottom Slab Concrete	M20	28/03/2019	25/04/2019	151.04 X 149.84 X 150.29	22632	**8.048**	521.4	23.0	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

AE-02

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 25/04/2019

Lab ID	:	**CP-2019-04-11-28**
Customer	:	Assistant Executive Engineer, Yelahanka Sub Division, BBMP, Bangalore.
Address	:	Yelahanka Sub Division, BBMP, Bangalore.
Project Name	:	Construction of Drain at Kote Bheedhi Near Venugopal Swamy Temple in Ward No-02 of Yelahanka Sub Division.
Agency	:	Sri.G.Muniraju, No:54, 4th Cross, 4th Main, Kote Street, Yelahanka, Bangalore-560064.
Customer's Reference	:	EE(YNK.D)E-PMT-19/W.O/31/2018-19
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	30-03-19
Customer ID	:	Drain Bottom Slab Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 25/04/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Bottom Slab Concrete	M20	28/03/2019	25/04/2019	149.52 X 149.84 X 151.43	22403	**8.444**	536.3	23.9	23.6
2	Drain Bottom Slab Concrete	M20	28/03/2019	25/04/2019	151.25 X 149.15 X 150.54	22559	**8.879**	516.2	22.9	
3	Drain Bottom Slab Concrete	M20	28/03/2019	25/04/2019	149.52 X 149.53 X 149.71	22359	**8.068**	536.2	24.0	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

AE-2 AE-02

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL PRO BANGALORE Sig..... Date.....

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 15/04/2019

Lab ID	:	**CP-2019-04-11-28**
Customer	:	Assistant Executive Engineer, Yelahanka Sub Division, BBMP, Bangalore.
Address	:	Yelahanka Sub Division, BBMP, Bangalore.
Project Name	:	Construction of Drain at Kote Bheedhi Near Venugopal Swamy Temple in Ward No-02 of Yelahanka Sub Division.
Agency	:	Sri.G.Muniraju, No:54, 4th Cross, 4th Main, Kote Street, Yelahanka, Bangalore-560064.
Customer's Reference	:	EE(YNK.D)E-PMT-19/W.O/31/2018-19
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	10-04-19
Customer ID	:	Cement Concrete Pavement
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	15/04/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Pavement	M20	08/04/2019	15/04/2019	150.29 X 151.39 X 151.93	22752	**8.665**	426.4	18.7	18.5
2	Cement Concrete Pavement	M20	08/04/2019	15/04/2019	150.04 X 149.58 X 149.39	22443	**8.419**	410.3	18.3	
3	Cement Concrete Pavement	M20	08/04/2019	15/04/2019	151.29 X 151.71 X 149.33	22952	**8.750**	426.4	18.6	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

AE-2 AE-2

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES

Scanned by CamScanner